

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0694:246 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Models ST-R and ST-W selectable candela, synchronizable strobes. For use in synchronized or non-synchronized circuits. Strobes used in synchronized circuits must be used with models SMR, SMW or FASM-R, FASM-W sync module, or any other source providing the Faraday sync protocol. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: Electrical: 16-33 VDC/FWR

Selectable Candela: 15cd, 30cd, 75cd or 110cd

Flash Rate: 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For wall and ceiling mount and indoor use only.

MARKING: Listee's name or "ML", model number, electrical rating and UL label.

APPROVAL: Listed as selectable type synchronizable strobe lights for the hearing impaired when used in conjunction with separately listed compatible with fire alarm control units. All units are suitable for wall or ceiling mounted. For indoor use only.

XLF: 7125-0065:169

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager